Message

From: Mannix, John [mannixj@monroe.wednet.edu]

Sent: 9/9/2016 9:17:39 PM

To: Moore, Kendall [moore.kendall@epa.gov]

CC: Jeff Ketchel [jketchel@snohd.org]; Mullin, Michelle [Mullin.Michelle@epa.gov]; Deka Smith [smithf@monroe.wednet.edu]; Devlin Piplic [piplicd@monroe.wednet.edu]; Karen Rosencrans

[RosencransK@monroe.wednet.edu]; Deviln Piplic [piplica@monroe.wednet.edu]; Karen Rosencrans [RosencransK@monroe.wednet.edu]; Peachey, Robert [peachey.robert@epa.gov]; Nancy Bernard

[nancy.bernard@doh.wa.gov]; Amanda Zych [azych@snohd.org]; Kevin Plemel [kplemel@snohd.org]; Ramanauskas,

Peter [ramanauskas.peter@epa.gov]; Mangino, Mario [mangino.mario@epa.gov]

Subject: Re: Completion of SVEC Corrective Action Plan
Attachments: Wipe SMPL (Misc Re-test) Report FINAL 1609-093.pdf

Kendall,

Here is a copy of the final QA/QC data for the wipe sample re-takes in the small gym and exterior of the Administration Building (NOT the Annex Building). I have asked Gregg Middaugh of PBS Environmental to assist me in providing the information requested in questions 2-5. I will forward that as soon as I receive it.

John

John Mannix Assistant Superintendent for Operations

200 E. Fremont Street Monroe, WA 98272 (360) 804-2579



Monroe Public Schools provides an outstanding education that results in all students having a passion for learning.

On Fri, Sep 9, 2016 at 2:05 PM, Moore, Kendall < moore.kendall@epa.gov > wrote:

Thank you for your completion report. In order to fully evaluate your results EPA requests the following:

- 1. Final QA/QC data for the wipe samples of small gym floor and exterior of Annex Building
- 2. Area (in square feet) of small gym floor and area exterior of Annex building that were recleaned
- 3. Rational for collecting one sample of the floor in the small gym
- 4. Please report all air sample quantitation limits/reporting limits as ng/m³

- 5. Were the wipe samples collected after caulk removal collected before or after epoxy encapsulation?
- 6. Explain the filter analysis procedure used for air samples run under Method TO-10A.

From: Mannix, John [mailto:mannixj@monroe.wednet.edu]

Sent: Friday, September 09, 2016 1:57 PM

To: Jeff Ketchel <<u>jketchel@snohd.org</u>>; Mullin, Michelle <<u>Mullin.Michelle@epa.gov</u>>; Moore, Kendall <moore.kendall@epa.gov>

Cc: Deka Smith < smithf@monroe.wednet.edu >; Devlin Piplic < piplicd@monroe.wednet.edu >; Karen Rosencrans < Rosencrans K@monroe.wednet.edu >; Nancy Bernard < nancy.bernard@doh.wa.gov >; Amanda Zych < azych@snohd.org >; Kevin Plemel < kplemel@snohd.org >

Subject: Re: Completion of SVEC Corrective Action Plan

Attached please find the revised notice of completion of the Corrective Action Plan for Sky Valley Education Center. I am not re-sending the twenty attachments containing the lab results and chain of custody documents. Those are all still valid and appropriate. I am therefore simply adding the two new documents related to the retesting of the PCB wipe test results that previously exceeded 10 ug/100 cm2.

Respectfully,

John Mannix

Assistant Superintendent for Operations

200 E. Fremont Street

Monroe, WA 98272

(360) 804-2579



Monroe Public Schools provides an outstanding education that results in all students having a passion for learning.

Any dissemination or use of this information by a person other than the intended recipient is unauthorized and may be illegal. If you have received this e-mail in error, please immediately notify us by return e-mail. All email to and from this domain is archived as a public record in compliance with federal and state requirements. As such they may be both discoverable in a legal action and available through a public records request.

Any dissemination or use of this information by a person other than the intended recipient is unauthorized and may be illegal. If you have received this e-mail in error, please immediately notify us by return e-mail. All

